

AIR SOURCE HEAT PUMPS – South

CEE Split Ducted ASHP Specifications – South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 11.7	≥ 7.8	N/A
CEE Advanced Tier	≥ 17.0	≥ 12.0	≥ 8.0	CEE Demand Response Criteria Level 2

CEE Non-Ducted ASHP Specification – South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 11.7	≥ 7.8	N/A
CEE Tier 2	≥ 16.0	≥ 12.0	≥ 9.0	N/A
CEE Advanced Tier	≥ 17.0	≥ 13.0	≥ 9.0	CEE Demand Response Criteria Level 2

CEE Packaged ASHP Specification – South				
Level	SEER2	EER2	HSPF2	Connectivity
CEE Tier 1	≥ 15.2	≥ 10.6	≥ 7.2	N/A
CEE Advanced Tier	≥ 16.0	≥ 11.0	≥ 8.0	CEE Demand Response Criteria Level 2